# **Symbio LABORATORIES**

	Symbio LABORATORIES quality solutions assured
L/2	ABN: 82 079 645 015
Brisbane	ABN: 82 079 645 015
Customer Serv	ice Team
52 Brandl Stree	et, Eight Mile Plains, QLD 4113
ndmin@symbio	olabs.com.au
1300 703 166	
07/04/2025 10	:25 NATA
07/04/2025 10	

Accreditation No: 2455 Accredited for compliance with ISO/IEC 17025 -

CERTIFICATE OF ANALYSIS			
Certificate Number	B1803756-2 [R00]	Page	1/2
Client	Cool Off	Registering Laboratory	Brisbane
Contact	Derrick Addison	Contact	Customer Service Team
Address	271 Jude Road Howlong NSW	Address	52 Brandl Street, Eight N
Address	2643	Email	admin@symbiolabs.com
Telephone	02 6026 5466	Telephone	1300 703 166
Order Number		<b>Date Samples Received</b>	07/04/2025 10:25
Job Description	Waste Water Sample - February	Date Analysis Commenced	07/04/2025 10:25
Client Job Reference		Issue Date	14/04/2025
No. of Samples Registered	1   Sampler: Customer	Receipt Temperature (°C)	23
Priority	Normal	Storage Temperature (°C)	4

This report supersedes any previous revision with this reference. This document must not be reproduced, except in full. If samples were provided by the customer, results apply only to the samples 'as received' and responsibility for representative sampling rests with the customer. Results are reported on as 'as is' basis unless otherwise indicated in the 'Report Comments' section. Measurement Uncertainty is available upon request. If the laboratory was authorised to conduct testing on samples received outside of the specified conditions, all test results may be impacted. Details of samples received outside of the specified conditions are mentioned in the sample description section of this test report.

#### **Definitions**

| <: Less Than | >: Greater Than | RP: Result Pending | ~: Estimated | MPN: Most Probable Number | CFU: Colony Forming Units | ---: Not Received/Not Requested | ^ Subcontracted Analysis | NA: Not Applicable | ND: Not Detected | [NT]: Not Tested | LOR: Limit of Reporting | TBA: To Be Advised | |\* Test not covered by NATA scope of accreditation | # Result derived from a calculation and includes results equal to or greater than the LOR | IH: Inconsistent results possibly caused by sample homogeneity |

#### **Authorised By**

Name	Position	Accreditation Category
Hongmei Kuang	Environmental Laboratory Manager, Brisbane	Environmental Chemistry

#### **Sample Information** - Client/Sampler Supplied

Sample ID	Sample Description	Remarks
B1803756/2	Waste Water Sample - February	

### **Analytical Results**

Compound/Analyte	Method	LOR	Units	Results
Boron (Total)	Total metals in water by ICPMS	0.005	mg/L	0.0094
Total Kjeldahl Nitrogen	EFF001 - Total Kjeldahl Nitrogen in Water/Effluent (APHA 4500-Norg B.)	1	mg/L	210
Nitrate (as N)	EFF004.1 - Nitrogen in Water/Effluent FIA (APHA 4500-NO3 F)	0.005	mg/L	0.0080
Nitrite (as N)	EFF005.1 - Nitrite N in Water by FIA (APHA 4500-NO2 B)	0.005	mg/L	0.069
рН	EFF006 - pH in Water/Effluent (APHA 4500-H+ B)	-	pH Unit	6.18
Electrical Conductivity	EFF007 - Electical Conductivity in Water (APHA 2510 B)	5	μS/cm	1120
Solids (Suspended)	EFF009 - Suspended Solids in Water (APHA 2540 D)	1	mg/L	820
Dissolved Solids	EFF010 - Dissolved Solids in Water (APHA 2540 C)	1	mg/L	1600
Chloride	ENV002 - Anions by IC	0.05	mg/L	84.8
Sulphate	ENV002 - Anions by IC	0.01	mg/L	30
Fluoride	EFF015 - Fluoride in Water (APHA 4500-F C)	0.05	mg/L	0.06
Oil & Grease	EFF021 - Oil & Grease (GRavimetric) in Water (APHA 5520 B)	2	mg/L	337
Ammonia	EFF044 - Ammonia N in Water by FIA (APHA 4500-NH3 G)	0.005	mg/L	86
BOD (5day)	EFF023 - BOD in Water (APHA 5210 B)	2	mg/L	1900
Total Phosphorus	EFF029.1 - Total N / P in Water by FIA (APHA 4500-P I)	0.01	mg/L	34
Γurbidity	EFF061 - Turbidity in Water (APHA 2130 B)	0.1	NTU	320
Nitrogen (Total) #	Nitrogen (Total) in Water/Effluent	1	mg/L	210

Page 2/2 Certificate Number Cool Off



## **Analytical Results**

Compound/Analyte	Method	LOR	Units	Results
Salinity (Total Soluble Salt)#	EFF041 - Salinity As Total Soluble Salt in Water (1:5) (APHA 2520B/1030E)	2	mg/L	720
Magnesium (Dissolved)	Dissolved metals in Water by ICPOES	0.05	mg/L	5.2
Calcium (Dissolved)	Dissolved metals in Water by ICPOES	0.1	mg/L	4.8
Alkalinity Total (CaCO3)	EFF031 - Alkalinity as CaCO3 in water (APHA 2320 B)	1	mg/L	188
Alkalinity Bicarb (CaCO3)	EFF031 - Alkalinity as CaCO3 in water (APHA 2320 B)	1	mg/L	188
Alkalinity Carbonate (CaCO3)	EFF031 - Alkalinity as CaCO3 in water (APHA 2320 B)	1	mg/L	<1
Alkalinity Hydroxide(CaCO3)	EFF031 - Alkalinity as CaCO3 in water (APHA 2320 B)	1	mg/L	<1
Residual Alkalinity	EFF031 - Alkalinity as CaCO3 in water (APHA 2320 B)	1	meq/L	1
Potassium (Total)	Acid Extractable (Total) Elements by ICP-AES	0.2	mg/L	53
Calcium (Total)	Acid Extractable (Total) Elements by ICP-AES	0.1	mg/L	12
Magnesium (Total)	Acid Extractable (Total) Elements by ICP-AES	0.05	mg/L	5.7
Sodium (Total)	Acid Extractable (Total) Elements by ICP-AES	1	mg/L	64

B1803756-02 [R00]

## **Analysis Location**

All in-house analysis was completed by Symbio Laboratories - Brisbane.

## **Report Comments**

Laboratory results for pH, chlorine or dissolved oxygen are for information purpose only - testing conducted outside recommended storage time of 0.25hr from sampling.