Symbio LABORATORIES



CERTIFICATE OF ANALYSIS				Proudly AUSTRALIAN	
Certificate Number	B1261848 [R00]	Page	1/2	ABN: 82 079 645 015	
Client	Cool Off	Registering Laboratory	Brisbane		
Contact	Carmel Trimble	Contact	Customer Service Team		
Address	271 Jude Road Howlong NSW 2643	Address	52 Brandl Street, Eight Mile Plains, QLD 4113		
		Email	admin@symbiolabs.co	om.au	
Telephone	02 6026 5466	Telephone	1300 703 166		
Order Number		Date Samples Received	06/02/2023	NATA	
Job Description	Water	Date Analysis Commenced	06/02/2023		
Client Job Reference		Issue Date	13/02/2023	Accreditation No: 2455	
No. of Samples Registered	1 Sampler: Customer	Receipt Temperature (°C)	25	Accredited for compliance with ISO/IEC 17025 - Testing	

This report supersedes any previous revision with this reference. This document must not be reproduced, except in full. If samples were provided by the customer, results apply only to the samples 'as received' and responsibility for representative sampling rests with the customer. Results are reported on as 'as is' basis unless otherwise indicated in the 'Report Comments' section. Measurement Uncertainty is available upon request. If the laboratory was authorised to conduct testing on samples received outside of the specified conditions, all test results may be impacted. Details of samples received outside of the specified conditions are mentioned in the sample description section of this test report.

Storage Temperature (°C)

Definitions

Priority

| <: Less Than | >: Greater Than | RP: Result Pending | ~: Estimated | MPN: Most Probable Number | CFU: Colony Forming Units | ---: Not Received/Not Requested | | ^ Subcontracted Analysis | NA:Not Applicable | [NT]:Not Tested | LOR:Limit of Reporting | TBA:To Be Advised | ND:Not Detected | * Test not covered by NATA scope of accreditation | # Result derived from a calculation and includes results equal to or greater than the LOR | IH: Inconsistent results possibly caused by sample homogeneity

Authorised By

Name	Position	Accreditation Category
Glen Rangott	Environmental Laboratory Manager, Brisbane	Environmental Chemistry

Sample Information - Client/Sampler Supplied

Sample ID	Sample Description	Remarks
B1261848/1	Waste Water Sample 7415	

Analytical Results

Compound/Analyte	Method	LOR	Units	B1261848/1
Total Kjeldahl Nitrogen	EFF001 - Nitrogen (Total Kjeldahl) in Water/Effluent	1	mg/L	110
Nitrate (as N)	EFF004.1 - Nitrate-Nitrogen in Water/Effluent FIA	0.005	mg/L	0.0060
Nitrite (as N)	EFF005.1 - Nitrite N in Water by FIA	0.005	mg/L	0.10
Nitrogen (Total) #	EFF085 - Nitrogen (Total) in Water/Effluent	1	mg/L	110
Salinity (Total Soluble Salt)#	EFF041 - Salinity Calculation	2	mg/L	690
рН	EFF006 - pH in Water/Effluent		pH Unit	5.46
Electrical Conductivity	EFF007 - Electical Conductivity in Water	5	μS/cm	1080
Solids (Suspended)	EFF009 - Suspended Solids in Water	1	mg/L	2200
Dissolved Solids	EFF010 - Dissolved Solids in Water	1	mg/L	430
Fluoride	EFF015 - Fluoride in Water	0.05	mg/L	0.12
Oil & Grease	EFF021 - Oil & Grease (Gravimetric) in Water	2	mg/L	1200
Ammonia	EFF044 - Ammonia N in Water by FIA	0.005	mg/L	90
BOD (5day)	EFF023 - BOD in Water	2	mg/L	2200
Total Phosphorus	EFF029.1 - Total N & P in Water by FIA	0.01	mg/L	33
Turbidity	EFF061 - Turbidity in Water	0.1	NTU	920
Chloride	ENV002 - Anions by IC	0.05	mg/L	48

Client Cool Off Certificate Number
Page 2/2



B1261848 [R00]

Analytical Results

Compound/Analyte	Method	LOR	Units	B1261848/1
Sulphate	ENV002 - Anions by IC	0.01	mg/L	1.7
Potassium (Total)	EWI02 - Total Elements in Water by ICPOES	0.2	mg/L	29
Calcium (Total)	EWI02 - Total Elements in Water by ICPOES	0.1	mg/L	49
Magnesium (Total)	EWI02 - Total Elements in Water by ICPOES	0.05	mg/L	10
Sodium (Total)	EWI02 - Total Elements in Water by ICPOES	1	mg/L	45
Alkalinity Bicarb (CaCO3)	EFF031 - Alkalinity as CaCO3 in water	1	mg/L	283
Alkalinity Carbonate (CaCO3)	EFF031 - Alkalinity as CaCO3 in water	1	mg/L	<1
Alkalinity Hydroxide(CaCO3)	EFF031 - Alkalinity as CaCO3 in water	1	mg/L	<1
Alkalinity Total (CaCO3)	EFF031 - Alkalinity as CaCO3 in water	1	mg/L	283
Boron (Total)	EWM02 - Total Elements in Water by ICPMS	0.005	mg/L	0.025

Analysis Location

All in-house analysis was completed by Symbio Laboratories - Brisbane.

Report Comments

Laboratory results for pH, chlorine or dissolved oxygen are for information purpose only - testing conducted outside recommended storage time of 0.25hr from sampling.